

**BOROUGH OF SEWICKLEY
WASTEWATER TREATMENT PLANT REPORT**

APRIL 2019

PUMP STATIONS

- Operate/maintain Maple Street, Chestnut Street, Boundary Street and Seibert Street Pump Stations.
- Operate/maintain the Waste Water Treatment Facility.
- Reports submitted to the Allegheny County Health Department and Department of Environmental Protection for the month of March.

OPERATIONS SUMMARY

	MONTHLY		YEAR TO DATE	
SEWAGE TREATED	23,533	MG	98,079	MG
NATURAL GAS USED	175,500	CF	878,000	CF
SLUDGE FILTERED	64,350	GAL.	230,475	GAL.
DIGESTER GAS USED	0	CF	0	CF
CHLORINE USED	505	LBS.	2,101	LBS.
POLYMER USED	193	LBS.	609	LBS.
SODA ASH	1,000	LBS.	3,250	LBS.
DRY SLUDGE HAULED	16.66	TONS	37.45	TONS
SEPTAGE RECEIVED	0	GAL.	0	GAL.

PA ONE CALLS

RECEIVED 20
 RESPONDED TO 20
 EMERGENCY PA ONE CALLS 1

Complaints

Received: 0
 Responded: 0

- Install replacement continuous bagging unit for the screenings on the Huber
- Repair the rear exit gate, adjust limits
- Took Delivery of polymer
- Adjust chain and grease final drive unit
- Grease and adjust the chain on the barscreen
- Took delivery of chlorine
- Unclog primary scum trough multiple times
- Clean aeration grates
- Clean the white WWTP truck
- Investigate sink hole in Beaver St. with Franco
- Tris State Maintenance located a broken lateral that was causing the sink hole in Beaver St. in front of house 341
- Schedule Stefaniks excavation to preform sink hole repair
- Adjust the chain on the drive unit for the Primary clarifier
- Grease motors, check valves, and air releases at the pump stations
- Veterans Plumbing re certified the potable water backflow preventers at the plant and pump stations
- Replace a drip trap for the digester gas line
- Have CWM preform the annual form 43 sludge analysis, Awaiting results
- Mow grass, spray weeds

